

Annual Drinking Water Quality Report for 2025
Four Corners Water System
Four Corners Boulevard, Hopewell Junction, NY 12533
(Public Water Supply ID# 1330614)

INTRODUCTION

To comply with State regulations, Four Corners Water will be annually issuing a report describing the quality of your drinking water. The purpose of this report is to raise your understanding of drinking water and awareness of the need to protect our drinking water sources. Last year, your tap water met all State drinking water health standards. We are proud to report that our system did not violate a maximum contaminant level or any other water quality standard. This report provides an overview of last year's water quality. Included are details about where your water comes from, what it contains, and how it compares to State standards.

If you have any questions about this report or concerning your drinking water, please contact VRI Environmental Services at (845) 677-3839. We want you to be informed about your drinking water.

WHERE DOES OUR WATER COME FROM?

In general, the sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activities. Contaminants that may be present in source water include: microbial contaminants; inorganic contaminants; pesticides and herbicides; organic chemical contaminants; and radioactive contaminants. In order to ensure that tap water is safe to drink, the State and the EPA prescribe regulations which limit the number of certain contaminants in water provided by public water systems. The State Health Department and the FDA's regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Our water system serves 759 people through 263 service connections. Our water source is groundwater drawn from three drilled wells. One well is located off of Four Corners Boulevard and two wells are located off of Sassafra Circle. Well 5, which is located off of Sassafra Circle was recently approved by DOH to be put online in 2023. One well is an artesian rock well and two are gravel wells. The rock well is disinfected with sodium hypochlorite and the gravel wells are filtered with cartridge filtration and disinfected with sodium hypochlorite prior to distribution in two separate water treatment facilities.

A level sensor in the 660,000 gallon storage tank located off of Four Corners Boulevard operates on a timer for the rock wells. The gravel well is operated seasonally on a timer when the demand increases.

The permitted water taking capacities per well are 64130 and 200 gallons per minute. In 2025, we pumped a total of 31,760,400 gallons at an average of 87,014 gallons per day.

ARE THERE CONTAMINANTS IN OUR DRINKING WATER?

As the State regulations require, we routinely test your drinking water for numerous contaminants. These contaminants include: total coliform, nitrate, primary inorganic compounds, lead and copper, principal organic compounds, total trihalomethanes, haloacetic acids, and radiologicals. The table presented below depicts which compounds were detected in your drinking water. The State allows us to test for some contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of our data, though representative, are more than one year old.

It should be noted that all drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPA's Safe Drinking Water Hotline (800-426-4791) or the Dutchess County Department of Health at (845) 486-3404.

Table for Detected Contaminants

| Contaminant | Violation Yes/No | Date of Sample | Level Detected (Avg/Max) (Range) | Unit Measurement | MCLG | Regulatory Limit (MCL, TT or AL) | Likely Source of Contamination |
|--|------------------|----------------|----------------------------------|------------------|------|----------------------------------|---|
| Chlorine Residual (Entry Points) | No | Yearly Average | 1.37 (Range = 0.56 – 2.61) | mg/L | n/a | 4.0 | Water additive used to control microbes. |
| Turbidity Entry Point | No | Yearly Average | 0.33 (Range = 0.19 – 0.58) | NTU | n/a | TT – 1.0 | Soil Runoff. |
| Copper * | No | September 2025 | 106 (Range = 7 – 219) | ug/L | 1300 | AL = 1300 | Corrosion of household plumbing systems; Erosion of natural deposits; leaching from wood preservatives. |
| Lead ** | No | September 2025 | 4 (Range = ND – 11.5) | ug/L | 0 | AL = 15 | Corrosion of household plumbing systems; Erosion of natural deposits. |
| Nitrate Water Treatment Plant #1 Entry Point | No | 3/25/2025 | 0.34 | mg/L | 10 | 10 | Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits. |
| Nitrate Water Treatment Plant #2 Entry Point | No | 3/25/2025 | 0.32 | mg/L | 10 | 10 | Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits. |
| Barium Water Treatment Plant #1 Entry Point | No | 12/14/2022 | 0.024 | mg/L | 2 | 2 | Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits. |
| Nickel Water Treatment Plant #1 Entry Point | No | 12/14/2022 | 0.0037 | mg/L | n/a | n/a | Corrosion of plumbing systems; Erosion of natural deposits. |
| Barium Water Treatment Plant #2 Entry Point | No | 3/21/2024 | 0.012 | mg/L | 2 | 2 | Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits. |

| Contaminant | Violation Yes/No | Date of Sample | Level Detected (Avg/Max) (Range) | Unit Measurement | MCLG | Regulatory Limit (MCL, TT or AL) | Likely Source of Contamination |
|--|------------------|----------------|----------------------------------|------------------|------|----------------------------------|--|
| Nickel Water Treatment Plant #2 Entry Point | No | 3/21/2024 | 0.0048 | mg/L | n/a | n/a | Corrosion of plumbing systems; Erosion of natural deposits. |
| Chromium Plant #2 Entry Point | No | 3/21/2024 | 4 | ug/L | 100 | 100 | Discharge from steel and pulp mills; Erosion of natural deposits. |
| Fluoride Plant #2 Entry Point | No | 3/21/2024 | 0.61 | mg/L | n/a | 2.2 | Erosion of natural deposits. Water additive that promotes strong teeth; Discharge from fertilizer and aluminum factories. |
| Total Trihalomethanes Plant #2 Distribution | No | 9/24/2025 | 13.70 | ug/L | n/a | 80 | By-product of drinking water chlorination needed to kill harmful organisms. TTHMs are formed when source water contains large amounts of organic matter. |
| Haloacetic Acids Plant #2 Distribution | No | 9/24/2025 | 8.3 | ug/L | n/a | 60 | By-product of drinking water disinfection needed to kill harmful organisms. |
| Total Trihalomethanes Plant #1 Distribution | No | 9/24/2025 | 28.60 | ug/L | n/a | 80 | By-product of drinking water chlorination needed to kill harmful organisms. TTHMs are formed when source water contains large amounts of organic matter. |
| Haloacetic Acids Plant #1 Distribution | No | 9/24/2025 | 10.0 | ug/L | n/a | 60 | By-product of drinking water disinfection needed to kill harmful organisms. |
| Perfluorooctanoic Acid (PFOA) Well 2 | No | Quarterly 2025 | 1.73 (Range = ND – 2.54) | ng/L | n/a | 10 | Released into the environment from widespread use in commercial and industrial applications. |
| Perfluorooctane Sulfonic Acid (PFOS) Well 2 | No | Quarterly 2025 | 0.233 (Range = ND – 0.931) | ng/L | n/a | 10 | Released into the environment from widespread use in commercial and industrial applications. |

Footnotes:

* The level presented represents the 90th percentile of the 10 sites tested. A percentile is a value on a scale of 100 that indicates the percent of a distribution that is equal to or below it. The 90th percentile is equal to or greater than 90% of the copper values detected at your water system. In this case, 10 samples were collected at your water system and the 90th percentile value is the reported value. The action level for copper was not exceeded at any of the sites tested.

** The level presented represents the 90th percentile of the 10 sites tested. A percentile is a value on a scale of 100 that indicates the percent of a distribution that is equal to or below it. The 90th percentile is equal to or greater than 90% of the lead values detected at your water system. In this case, 10 samples were collected at your water system and the 90th percentile value is the reported value. The action level for lead was not exceeded at any of the sites tested.

The following tests were sampled in 2025 and were non-detected:

1,4 Dioxane (Well 2, 4, 5)

PFOA/PFOS (Well 4 & 5)

Principal Organic Chemicals – Well 5

Table of Unregulated Detected Contaminants

| Contaminant | Date of Sample | Level Detected (Max) (Range) | Unit Measurement | MCLG or Health Advisory Level | Likely Source of Contamination | | | | |
|-------------------------------------|-------------------------------|---|------------------|-------------------------------|--|--------------------------------------|------|---------|--|
| Perfluorobutanesulfonic Acid (PFBS) | Well 2 | 3/26/2025 6/24/2025 9/22/2025 12/18/2025 | ng/L | 2000 (1) | Released into the environment from widespread use in commercial and industrial applications. | | | | |
| | | 24.3 18.9 21.7 25.7 | | | | | | | |
| | Well 4 | 12/18/2025 | | | | 1.13 | | | |
| | Well 5 | 3/26/2025 | | | | 1.86 | | | |
| | | 9/22/2025 12/18/2025 | | | | 2.69 2.24 | | | |
| Perfluorobutanoic Acid (PFBA) | Well 2 | 3/26/2025 6/24/2025 9/22/2025 12/18/2025 | ng/L | n/a (2) | Released into the environment from widespread use in commercial and industrial applications. | | | | |
| | | 3.85 2.86 3.47 4.58 | | | | | | | |
| | Well 5 | 12/18/2025 | | | | 0.796 | | | |
| | Pefluorohexanoic Acid (PFHxA) | Well 2 | | | | 6/24/2025 9/22/2025 12/18/2025 | ng/L | n/a (2) | Released into the environment from widespread use in commercial and industrial applications. |
| | | | | | | 6.41 8.63 1.65 | | | |
| | | | | | | | | | |
| Perfluoropentanoic Acid (PFPeA) | Well 2 | 6/24/2025 9/22/2025 12/18/2025 | ng/L | n/a (2) | Released into the environment from widespread use in commercial and industrial applications. | | | | |
| | | 2.46 2.98 2.04 | | | | | | | |
| | | | | | | | | | |

| Contaminant | Date of Sample | Level Detected (Max) (Range) | Unit Measurement | MCLG or Health Advisory Level | Likely Source of Contamination |
|---|----------------|------------------------------|------------------|-------------------------------|--|
| Perfluoroheptanoic Acid (PFHpA) Well 2 | 12/18/2025 | 0.788 | ng/L | n/a (2) | Released into the environment from widespread use in commercial and industrial applications. |

Footnotes:

(1) 1 USEPA Health Advisory Levels identify the concentration of a contaminant in drinking water at which adverse health effects and/or aesthetic effects are not anticipated to occur over specific exposure durations. Health Advisory Levels are not to be construed as legally enforceable federal standards and are subject to change as new information becomes available.

(2) All perfluoroalkyl substances, besides PFOA and PFOS, are considered Unspecified Organic Contaminants (UOC) which have an MCL = 0.05 mg/L.

Definitions:

Non - Detects (ND) - Laboratory analysis indicates that the constituent is not present.

Milligrams per liter (mg/l) – Corresponds to one part of liquid in one million parts of liquid (parts per million – ppm).

Micrograms per liter (ug/l) – Corresponds to one part of liquid in one billion parts of liquid (parts per billion – ppb).

Action Level (AL) - The concentrations of a contaminant, which, if exceeded, triggers treatment, or other requirements, which a water system must follow.

Maximum Contaminant Level (MCL) - The highest level of a contaminant that is allowed in drinking water. MCL's are set as close to the MCLG's as feasible.

Maximum Contaminant Level Goal (MCLG) - The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLG's allow for a margin of safety.

Maximum Residual Disinfectant Level (MRDL) – The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG) – The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contamination.

Treatment Technique (TT) – A required process intended to reduce the level of a contaminant in drinking water.

Nanograms per liter (ng/L) – Corresponds to one part of liquid to one trillion parts of liquid (parts per trillion – ppt).

WHAT DOES THIS INFORMATION MEAN?

As you can see by the table, our system had no violations. We have learned through our testing that some contaminants have been detected; however, these contaminants were detected below the level allowed by the State. We are required to present the following information on lead in drinking water.

Lead can cause serious health effects in people of all ages, especially pregnant people, infants (both formula-fed and breastfed), and young children. Lead in drinking water is primarily from materials and parts used in service lines and in home plumbing. Four Corners Water is responsible for providing high quality drinking water and removing lead pipes but cannot control the variety of materials used in the plumbing in your home. Because lead levels may vary over time, lead exposure is possible even when your tap sampling results do not detect lead at one point in time. You can help protect yourself and your family by identifying and removing lead materials within your home plumbing and taking steps to reduce your family's risk. Using a filter, certified by an American National Standards Institute accredited certifier to reduce lead, is effective in reducing lead exposures. Follow the instructions provided with the filter to ensure the filter is used properly. Use only cold water for drinking, cooking, and making baby formula. Boiling water does not remove lead from water. Before using tap water for drinking, cooking, or making baby formula, flush your pipes for several minutes. You can do this by running your tap, taking a shower, doing laundry or a load of dishes. If you have a lead service line or galvanized requiring replacement service line, you may need to flush your pipes for a longer period. If you are concerned about lead in your water and wish to have your water tested, contact VRI Environmental Services for Four Corners Water. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available at <https://www.epa.gov/safewater/lead>.

IS OUR WATER SYSTEM MEETING OTHER RULES THAT GOVERN OPERATIONS?

During 2025, our system was in compliance with applicable State drinking water monitoring and reporting requirements.

INFORMATION ON LEAD SERVICE LINE INVENTORY

A Lead Service Line (LSL) is defined as any portion of pipe that is made of lead which connects the water main to the building inlet. An LSL may be owned by the water system, owned by the property owner, or both. The inventory includes both potable and non-potable SLs within a system. In accordance with the federal Lead and Copper Rule Revisions (LCRR) our system has prepared a preliminary lead service line inventory and have made it publicly accessible by visiting https://www.health.ny.gov/environmental/water/drinking/service_line/NY1330614.htm

DO I NEED TO TAKE SPECIAL PRECAUTIONS?

Although our drinking water met or exceeded state and federal regulations, some people may be more vulnerable to disease causing microorganisms or pathogens in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice from their health care provider about their drinking water. EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium, Giardia and other microbial pathogens are available from the Safe Drinking Water Hotline (800-426-4791).

WHY SAVE WATER AND HOW TO AVOID WASTING IT?

Although our system has an adequate amount of water to meet present and future demands, there are a number of reasons why it is important to conserve water:

- ◆ Saving water saves energy and some of the costs associated with both of these necessities of life;
- ◆ Saving water reduces the cost of energy required to pump water and the need to construct costly new wells, pumping systems and water towers; and
- ◆ Saving water lessens the strain on the water system during a dry spell or drought, helping to avoid severe water use restrictions so that essential fire fighting needs are met.

You can play a role in conserving water by becoming conscious of the amount of water your household is using, and by looking for ways to use less whenever you can. It is not hard to conserve water. Conservation tips include:

- ◆ Automatic dishwashers use 15 gallons for every cycle, regardless of how many dishes are loaded. So get a run for your money and load it to capacity.
- ◆ Turn off the tap when brushing your teeth.
- ◆ Check every faucet in your home for leaks. Just a slow drip can waste 15 to 20 gallons a day. Fix it up and you can save almost 6,000 gallons per year.
- ◆ Check your toilets for leaks by putting a few drops of food coloring in the tank, watch for a few minutes to see if the color shows up in the bowl. It is not uncommon to lose up to 100 gallons a day from one of these otherwise invisible toilet leaks. Fix it and you save more than 30,000 gallons a year.

CLOSING

Thank you for allowing us to continue to provide your family with quality drinking water this year. In order to maintain a safe and dependable water supply we sometimes need to make improvements that will benefit all of our customers. The costs of these improvements may be reflected in the rate structure. Rate adjustments may be necessary in order to address these improvements. We ask that all our customers help us protect our water sources, which are the heart of our community. Please call our office if you have any questions.